TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **coating**

Article description:	LOBADUR 2K FactoryStyle
Kind of material:	mineral filler with factory-made coating structure
Material structure:	1. Substrate: mineral filler 2. Primer: 1x LOBADUR FactoryBase (consumption: 100 g/m²) 3. Sealing: 1x LOBADUR 2K FactoryStyle (consumption: 120 g/m²)
Colour:	cement grey, cloudy
Dimensions:	variable, Test samples: 1000 x 500 x 5 [mm]
Surface:	unprofiled, even, fine-rough, lacquered
Producer/supplier:	LOBA GmbH & Co. KG Leonberger Str. 56-62 71254 Ditzingen

Client: LOBA GmbH & Co. KG
Leonberger Str. 56-62
71254 Ditzingen

Certificate No.: 92032001.001e

Test date: 06.11.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property - Workrooms and fields of activities with slip danger - Walking method - Ramp test"

The delivery of the test material took place in ready-to-test surface condition.

Test result: Average total acceptance angle: **7,7°**

Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director

Dipl.-Ing. Friedrich Höltkemeyer

Institut für physikalisch und chemisch beanspruchte Wand- und Bodenbeläge
SFV
Säurefliesner-Vereinigung e.V.
Großburgwedel

Großburgwedel, 15.02.2021
Schu/ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.